

APR - 3 1974

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford
CHECK ONE Town Village City NAME Bridgeport

2. LOCATION - 1/4 Section Section Township Range
Part of F.L. 41-42 of Private Land
Street name
Claims E. of Hwy. V. 178/260 3A
3. OWNER AT TIME OF DRILLING
Vernon Koresh
ADDRESS
RFD 2
POST OFFICE
Praire Du Chien, Wisc.

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C.I.	C.I.	C.I.	SEWER CONNECTED	INDEPENDENT
TILE	TILE	TILE		
20'	40'	65'	None	None
CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD
C.I.	TILE			
None	40'	None	60'	None
BARN	SILO	ABANDONED WELL	SINK HOLE	
None		None	None	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)
None

5. Well is intended to supply water for:
Residence

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
8"	Surface	136'				Caving Orange Sand	Surface	45
						" Black "	45	70
						" Gray Mud	70	80
6"	New Steel P.E.			Surface	115'	" Black Sand	80	111
	18.974 per ft.					Gray Limestone	111	136

8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)		<input checked="" type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	
Drive Shoe	Surface	115		<input type="checkbox"/> Rotary - air w/drilling mud	<input type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with Air <input type="checkbox"/> Water	
				Well construction completed on 3-20 1974			

11. MISCELLANEOUS DATA			
Yield test:	4	Hrs. at	20 GPM
Depth from surface to normal water level	40	ft.	
Depth to water level when pumping	60	ft.	
Well is terminated		12 inches	<input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below
Well disinfected upon completion			<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Well sealed watertight upon completion			<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to State lab. of Hygiene; Madison, Wisc., laboratory on: 3-26 1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE *Duane Lubbers* W.D. 410 Registered Well Driller
COMPLETE MAIL ADDRESS
Duane Lubbers
Farmersburg, Iowa 52047

Please do not write in space below

COLIFORM TEST RESULT 278 REV. 3-71	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
--	---------------	---------------	-----------	---------