

Copies as T6N R6W Sec. UNLOC
 + UNLOC. for County NOTE: FEB 18 1977

State of Wisconsin
 Department of Natural Resources
 Box 450
 Madison, Wisconsin 53701

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
 Form 3300-15
 Rev. 10-75

1. COUNTY Crawford CHECK (X) ONE: Town Village City Name Bridgeport

2. LOCATION NW Section 6 Township T6N Range R6E 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (X) ONE Ralph Schneider

OR - Grid or Street No. Street Name R5W?? ADDRESS

AND - If available subdivision name, lot & block No. POST OFFICE Bridgeport

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To		Storm Bldg. Drain		Storm Bldg. Sewer	
	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer: San. Storm Other Sewers: C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump

Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit: Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Line stock

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	27			
6	27	64			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay	Surface	22
Sandstone	22	64

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6"	New steel to c. 19.45' surface A-53 youngstown	27	

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	Surface	27

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 8-2 1976

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 25 GPM

Well is terminated 8' inches above final grade below

Depth from surface to normal water level 30 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 30 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Feb 8 1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph Faherty Registered Well Driller Complete Mail Address Faherty Drilling Co., Inc.
1130 Broadway
EAU CLAIRE, WISCONSIN 54806

WGNHS ORIGINAL

279