

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH

See Instructions on Reverse Side

1. County Crawford Town Village City Bridge Port, Wis. Check one and give name

2. Location Sec # 3 - Block 6 - Range 6 W. T-6N Name of street and number of premise or Section, Town and Range numbers

3. Owner or Agent Louis Beneben Name of individual, partnership or firm

4. Mail Address Prairie du Chien, Wis R. F. D # 2. Complete address required

5. From well to nearest: Building 10 ft; sewer ft; drain ft; septic tank ft; dry well or filter bed ft; abandoned well ft.

6. Well is intended to supply water for: Stock Well.

7. DRILLHOLE:

Table with columns: Dia. (in.), From (ft.), To (ft.), Dia. (in.), From (ft.), To (ft.). Rows: 12" 0 6', 6 6 229.

8. CASING AND LINER PIPE OR CURBING:

Table with columns: Dia. (in.), Kind and Weight, From (ft.), To (ft.). Row: 6" Heavy duty Blk Steel pipe 123 ft used.

9. GROUT:

Table with columns: Kind, From (ft.), To (ft.).

11. MISCELLANEOUS DATA:

Yield test: 10 Hrs. at 6 GPM. Depth from surface to water-level: 180 ft. Water-level when pumping: Same ft. Water sample was sent to the state laboratory at: Madison - Test # 1 Aug 25-53 - unsafe. Test # 2 - Aug 3, 1953 - Safe. 19

10. FORMATIONS:

Table with columns: Kind, From (ft.), To (ft.). Rows: Heavy Soil 0 15, Gravel-Sand water 15 223, Sand Stone 223 229.

RECEIVED AUG 15 1957 ENVIRONMENTAL SANITATION

Construction of the well was completed on: August 18 1953

The well is terminated 16 inches above, below the permanent ground surface.

Was the well disinfected upon completion? Yes Yes No

Was the well sealed watertight upon completion? Yes Yes No

Signature H. W. Bartels P.O. Box 175 - Bescohel, Wis. Registered Well Driller Complete Mail Address

Rec'd No. Ans'd Interpretation

10 ml 10 ml 10 ml 10 ml 10 ml Gas-24 hrs. 48 hrs. Confirm B. Coli Examiner