

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City <u>Bridgeport</u>	
2. LOCATION		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE	
1/4 Section <u>SE</u>	Section <u>3</u>	Township <u>3N</u>	Range <u>6W</u>
OR - Grid or Street No. <u>6</u> Street Name <u>T6N R6W</u>		ADDRESS <u>RFD</u>	
AND - If available subdivision name, lot & block No.		POST OFFICE <u>Orsiredu Chien, WI 53821</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block)			
Building <u>15'</u>	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:
	C.I. Other	C.I. Other	C.I. Sewer Other Sewer
Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump
San. Storm	C.I. Other	Sewer Sewage Sump Clearwater Dr.	Clearwater Sump
			Septic Tank <u>110'</u>
			Holding Tank
			Sewage Absorption Unit <u>150'</u>
			Seepage Pit
			Seepage Bed
			Seepage Trench
Privy	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter
Pet Waste Pit	Well Pump Tank	Nonconforming Existing	Animal Barn Pen
			Animal Yard
			Silo With Pit
			Glass Lined Storage Facility
			Silo w/o Pit
			Earthen Silage Storage Trench Or Pit
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank
			Waste Pond or Land Disposal Unit (Specify Type)
			Other (Give Description)
5. Well is intended to supply water for: <u>Country Home</u>		9. FORMATIONS	
6. DRILLHOLE		Kind	From (ft.) To (ft.)
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)
<u>10</u>	<u>0</u> Surface	<u>159</u>	<u>6</u> <u>159</u> <u>180</u>
			<u>Clay</u> Surface <u>12</u>
			<u>Limestone</u> <u>12</u> <u>80</u>
			<u>Clay & Broken Limestone</u> <u>80</u> <u>145</u>
			<u>Hard Sandstone</u> <u>145</u> <u>180</u>
7. CASING, LINER, CURBING AND SCREEN		10. TYPE OF DRILLING MACHINE USED	
Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>P.E. New Black Steel</u>	<u>0</u> Surface	<u>159</u>
	<u>18.47 Valley Steel A-53</u>		
	<u>Pitless Adaptor</u>		
8. GROUT OR OTHER SEALING MATERIAL		<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-air w/drilling mud <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water	
Kind	From (ft.)	To (ft.)	
<u>Clay</u>	<u>0</u> Surface	<u>7</u>	
<u>Cement</u>	<u>7</u>	<u>159</u>	
11. MISCELLANEOUS DATA		Well construction completed on <u>Jan. 7</u> 1977	
Yield Test: <u>4</u> Hrs. at <u>6</u> GPM	Well is terminated <u>10</u> inches	<input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below	
Depth from surface to normal water level <u>115</u> Ft.	Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth of water level when pumping <u>128</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Water sample sent to <u>Madison</u> laboratory on <u>Jan. 25</u> 19 <u>77</u>			

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 284
Kenneth Coplan Registered Well Driller

Complete Mail Address
R3, Box 84 - Boscobel, WI