

SEP 21 1971

WELL CONSTRUCTOR'S REPORT

Well-6

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Bridgeport

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
SE 1/4 of Sec. 3 T-6-3N R-6-3W

3. OWNER AT TIME OF DRILLING Robert Korosh

4. OWNER'S COMPLETE MAIL ADDRESS R2 Prairie du Chien Wis., 53821

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
50	60		60			60	

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		120			130				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Country home

7. DRILLHOLE 10. FORMATIONS

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	83	6	83	120	Clay	Surface	18
						broken limestone	18	25

8. CASING, LINER, CURBING, AND SCREEN Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	10. FORMATIONS Kind	From (ft.)	To (ft.)
6	new black steel plain end 1 7/8	Surface	83	limestone	25	60
				Clay	60	70
				sandstone	70	120

9. GROUT OR OTHER SEALING MATERIAL Kind	From (ft.)	To (ft.)
Clay	Surface	18
Cement	18	83

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 10 GPM Well is terminated 10 inches  above  below final grade

Depth from surface to normal water level 75 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 85 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 9-16-1971

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Cyprian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>285</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------