

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Bridgeport

2. LOCATION  $\frac{1}{4}$  Section NW Section 9 Township 6N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
OR - Grid or Street No. Street Name ADDRESS John Karnopp  
R2 Box 416  
AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, Wis 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump Sewage Absorption Unit 125' Seepage Pit Seepage Bed Seepage Trench

5. Well is intended to supply water for: Country home 9. FORMATIONS Kind From (ft.) To (ft.)  
loose sand & Clay Surface 0 25  
limestone 25 80  
hard sandstone 80 120

6. DRILLHOLE Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)  
10 Surface 0 41 6 41 120

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly Dia. (in.) From (ft.) To (ft.)  
new black steel 6 P.E. 18.77 Surface 0 41  
A-53  
Valley Steel  
Pitless adaptor

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)  
Clay Surface 0 7  
Cement 7 41

10. TYPE OF DRILLING MACHINE USED  
 Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water  
 Rotary-air w/drilling mud  Rotary-hammer & air  
 Rotary-w/drilling mud  Reverse Rotary

11. MISCELLANEOUS DATA Yield Test: 3 Hrs. at 5 GPM Well is terminated 12 inches  above final grade  below  
Depth from surface to normal water level 60 Ft. Well disinfected upon completion  Yes  No  
Depth of water level when pumping 68 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No  
Water sample sent to Madison laboratory on 4-17- 19 78

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address R3 Box 84 Boscobel, Wis. 53805