

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

APR 29 1976

APR 15 1976

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Bridgport

2. LOCATION - 1/4 Section NE Section 9 Township T6N Range R6W 3. OWNER AT TIME OF DRILLING Rod Laurille  
OR - Grid or street no. Street name ADDRESS

AND - If available subdivision name, lot & block no. POST OFFICE Prarie Du Chen

4. Distance in feet from well to nearest: BUILDING SANITARY SEWER FLOOR DRAIN FOUNDATION DRAIN WASTE WATER DRAIN  
(Record answer in appropriate block) 7 C. I. TILE C. I. TILE SEWER CONNECTED INDEPENDENT C. I. TILE

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE  
C. I. TILE 70 85

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	70				Clay	Surface	3
6	70	144				Loose sand	3	25

7. CASING, LINER, CURBING, AND SCREEN				9. FORMATIONS		
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<del>6</del>	<del>New steel 7 x c 19.18</del>	<del>Surface</del>	<del>70</del>	Shale	35	50
6	New steel 7 x c 19.45	70	70	Cambrian (soft)	50	70
	A-53 grumpston			Cambrian sandstone	70	144

8. GROUT OR OTHER SEALING MATERIAL Kind Cement From (ft.) Surface To (ft.) 70

10. TYPE OF DRILLING MACHINE USED  
 Cable Tool  Direct Rotary  Reverse Rotary  
 Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water  
 Well construction completed on 10-21 1975

11. MISCELLANEOUS DATA  
 Yield test: 2 Hrs. at 25 GPM Well is terminated 8 inches  above  below final grade  
 Depth from surface to normal water level 80 ft. Well disinfected upon completion  Yes  No  
 Depth to water level when pumping 80 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: April 12 1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Ralph J. Faherty Registered Well Driller COMPLETE FAHERTY DRILLING CO., INC.  
1120 Broadway PLATTEVILLE, WISCONSIN 53818

COLIFORM TEST RESULT 294 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS  
REV. 3-71