State of Wisconsin
Department of Natural Resources
Box 7921
Madison, Wisconsin 53707

NOTE:
White Copy – Division's Copy
Green Copy – Driller's Copy
Yellow Copy – Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15 Rev. 12-76

WCD
JUL 20 1981
JUN 4 1981

1. COUNTY Crawford

CHECK (✓) ONE: ☑ Town ☐ Village ☐ City Name Wauzeka

2. LOCATION ¼ Section: SE | Section: 28 | Township: 7N | Range: 5W

OR – Grid or Street No. | Street Name

AND – If available subdivision name, lot & block No.

3. NAME ☒ OWNER ☐ AGENT AT TIME OF DRILLING CHECK (✓) ONE
Burt Anderson

ADDRESS
Rt 1

POST OFFICE
Wauzeka, WI 53826

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain C.I.	Sanitary Bldg. Drain Other	Sanitary Bldg. Sewer C.I.	Sanitary Bldg. Sewer Other	Floor Drain Connected To: C.I. Sewer	Floor Drain Connected To: Other Sewer	Storm Bldg. Drain C.I.	Storm Bldg. Drain Other	Storm Bldg. Sewer C.I.	Storm Bldg. Sewer Other
15'			35'							

Street Sewer San.	Street Sewer Storm	Other Sewers C.I.	Other Sewers Other	Foundation Drain Connected to: Sewer	Sewage Sump	Clearwater Dr.	Clearwater Sump	Sewage Sump C.I.	Sewage Sump Other	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	
											60'		Seepage Pit	
													Seepage Bed	
													Seepage Trench	

90'

Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom Nonconforming Existing	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well									
		Pump									
		Tank									

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0 Surface	40	6"	40	120

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97#/ft	0 Surface	40
	A53-		
	pitless adapter		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	0 Surface	8
cement	8	40

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay	0 Surface	15
Hard Limestone	15	60
Hard Shalestone	60	120

10. TYPE OF DRILLING MACHINE USED

☐ Cable Tool
☐ Rotary-air w/drilling mud
☐ Rotary-w/drilling mud
☐ Rotary-hammer w/drilling mud & air
☒ Rotary-hammer & air
☐ Reverse Rotary
☐ Jetting with ☐ Air ☐ Water

Well construction completed on 11-14 1980

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM

Depth from surface to normal water level 75 Ft.

Depth of water level when pumping 80 Ft. Stabilized ☒ Yes ☐ No

Well is terminated 15 inches ☒ above ☐ below final grade

Well disinfected upon completion ☒ Yes ☐ No

Well sealed watertight upon completion ☒ Yes ☐ No

Water sample sent to Madison laboratory on 5-26 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Phil Caplan Registered Well Driller

Complete Mail Address 308 E. Bluff - Boscobel, WI 53805

30