

DNR

White Copy
Green Copy
Yellow Copy

NOTE:

Division's Copy
Driller's Copy
Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Bridgeport

2. LOCATION NW Section 10 Township UN Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
ADDRESS RR R6W Name John Jones

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, WI

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Storm Bldg. Drain	Storm Bldg. Sewer
<u>20'</u>	C.I. <u>35'</u> Other	C.I. Other	C.I. Other	C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump

Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 75

Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumphouse Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>0</u>	<u>110</u>	<u>6</u>	<u>110</u>	<u>140</u>	<u>Clay</u>	<u>Surface</u>	<u>20</u>
						<u>Limestone</u>	<u>20</u>	<u>50</u>
						<u>sandstone</u>	<u>50</u>	<u>140</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>P.E. New Block Steel</u>	<u>Surface</u>	<u>110</u>
	<u>A-53 18.97</u>		
	<u>Valley Steel</u>		
	<u>Pitless Adaptor</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>110</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air Reverse Rotary

Rotary-w/drilling mud

Well construction completed on May 5 19 77

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches above below final grade

Depth from surface to normal water level 90 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 100 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on May 9 19 77

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller

Complete Mail Address R3, Box 84 - Boscobel, WI