

MAY 18 1970

Well 6

## WELL CONSTRUCTOR'S REPORT

## DEPARTMENT OF RESOURCE DEVELOPMENT

1. COUNTY Crawford		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		NAME Bridgeport				
2. LOCATION (Number and Street or ¼ section, section, township and range. Also give subdivision name, lot and block numbers when available.) SW ¼ NW ¼ Sec. 10 T-6-N R-6-W								
3. OWNER AT TIME OF DRILLING Harley Eggleston								
4. OWNER'S COMPLETE MAIL ADDRESS RFD 2 Box 211 Prairie Du Chien								
5. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING 30'	SANITARY SEWER C.I. X TILE	FLOOR DRAIN C.I. None TILE	FOUNDATION DRAIN SEWER CONNECTED None INDEPENDENT	WASTE WATER DRAIN C.I. None TILE		
CLEAR WATER DRAIN C.I. None TILE	SEPTIC TANK 100'	PRIVY None	SEEPAGE PIT None	ABSORPTION FIELD 200'	BARN 200'	SILLO 250'		
					ABANDONED WELL 200'	SINK HOLE None		
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.) None								
6. Well is intended to supply water for: Farmstead								
7. DRILLHOLE			10. FORMATIONS					
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	120 ¼	6	120 ¼	180	Ground	Surface	2
						Sandy Clay	2	40
8. CASING, LINER, CURBING, AND SCREEN								
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)				
6	Steel P.E. 18.97#		Surface	120 ¼		Brown Rock	40	65
						Sandy Brown Rock	65	82
						White&Brown Flint Rock	82	85
						Sandy Brown Rock	85	104
						Jordan Sandstone	104	180
9. GROUT OR OTHER SEALING MATERIAL								
Kind		From (ft.)	To (ft.)					
Neat Cement Grout		Surface	120 ¼					
11. MISCELLANEOUS DATA								
Yield test:	4	Hrs. at	12	GPM		Well construction completed on	5-9	1970
Depth from surface to normal water level		119		ft.	Well is terminated	10	inches	<input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth to water level when pumping		130		ft.	Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
					Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to			State Lab. of Hygiene at Madison			laboratory on:		5-11 1970
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphouses, access pits, etc., should be given on reverse side. Welded Joints								
SIGNATURE Duane Lubbers Duane Lubbers			#WD 410 Registered Well Driller			COMPLETE MAIL ADDRESS Duane Lubbers Farmersburg, Iowa 52047		
Please do not write in space below								
COLIFORM TEST RESULT 302		GAS - 24 HRS.		GAS - 48 HRS.		CONFIRMED		REMARKS