

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Bridgeport

2. LOCATION 1/4 Section NE Section 10 Township 6N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
Duane E. Hilke  
 OR - Grid or Street No. Street Name ADDRESS R2 Box 403  
 AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Holding Tank Septic Tank Sewage Absorption Unit 115' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home 9. FORMATIONS Kind From (ft.) To (ft.)  
Clay Surface 0 25  
hard limestone 25 100  
sandstone 100 160

6. DRILLHOLE Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)  
10 Surface 0 42 6 42 160

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly Dia. (in.) From (ft.) To (ft.)  
new black steel P.E. 18.97 A-53 Surface 0 42  
Valley steel Pitless adaptor

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)  
Clay Surface 0 7  
Cement 7 42

10. TYPE OF DRILLING MACHINE USED  
 Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water  
 Rotary-air w/drilling mud  Rotary-hammer & air  
 Rotary-w/drilling mud  Reverse Rotary

Well construction completed on 8-28-1978

11. MISCELLANEOUS DATA Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches  above final grade  below  
 Depth from surface to normal water level 90 Ft. Well disinfected upon completion  Yes  No  
 Depth of water level when pumping 102 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No  
 Water sample sent to Madison laboratory on 8-30-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cophon Registered Well Driller Complete Mail Address Boscobel, Wis. R3 Box 84 53805