

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Bridgeport

2. LOCATION 1/4 Section NE Section 11 Township T6N Range R1W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
 OR - Grid or Street No. Street Name (6) ADDRESS John Kurt

AND - If available subdivision name, lot & block No. POST OFFICE Prarie du Chien

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 40 Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Sewage Sump Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 75 95

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumphoom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Home

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	Surface	<u>5</u>
<u>Clay sand + gravel</u>	<u>5</u>	<u>34</u>
<u>sandstone</u>	<u>34</u>	<u>64</u>

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	Surface	<u>40</u>			
<u>6</u>	<u>40</u>	<u>64</u>			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6" New</u>	<u>Steel T &amp; C 19.45</u>	Surface	<u>40</u>
	<u>A-53 youngstown</u>		

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air  Reverse Rotary

Rotary-w/drilling mud

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Cement</u>	Surface	<u>40</u>

Well construction completed on 8-10 1977

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 30 GPM

Depth from surface to normal water level 20 Ft.

Depth of water level when pumping 20 Ft. Stabilized  Yes  No

Well is terminated 8 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on Feb 16 1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph Faherty Registered Well Driller

Complete Mail Address **FABERTY DRILLING CO., INC.**  
 1120 Broadway  
 PLATTEVILLE, WISCONSIN 53818