

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Wauseka	
2. LOCATION 1/4 Section SW Section 29 Township 7N Range 5W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE		ADDRESS Francis W. Schneider	
OR - Grid or Street No. Street Name		POST OFFICE Paris du Chien, WI 53820		RFD	
AND - If available subdivision name, lot & block No.					
4. Distance in feet from well to nearest: (Record answer in appropriate block) 15'		Building		Sanitary Bldg. Drain	
		Sanitary Bldg. Sewer		Floor Drain Connected To:	
		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I.		C.I.	
		Other		Other	
		C.I. Sewer		Other Sewer	
		C.I.		Other	
		C.I.		Other	
		C.I.		Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm		C.I. Other		Sewage Sump	
				Clearwater Sump	
				Septic Tank	
				Holding Tank	
				Sewage Absorption Unit	
				Seepage Pit	
				Seepage Bed	
				Seepage Trench	
Privy		Pet Waste Pit		Pit: Nonconforming Existing	
				Well	
				Pump	
				Tank	
				Subsurface Pumproom	
				Nonconforming Existing	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: Country home		6. DRILLHOLE			
		Dia. (in.)		From (ft.)	
		To (ft.)		Dia. (in.)	
				From (ft.)	
				To (ft.)	
				Kind	
				From (ft.)	
				To (ft.)	
				Clay	
				Surface 0 30	
				soft shale stone 30 80	
				hard shale stone 80 120	
7. CASING, LINER, CURBING AND SCREEN		Material, Weight, Specification & Method of Assembly			
Dia. (in.)		From (ft.)		To (ft.)	
6		Surface 0		95	
				new black steel	
				P.E. 18.97	
				A-53	
				Kent Steel	
				Pitless adapter	
8. GROUT OR OTHER SEALING MATERIAL		Kind			
		From (ft.)		To (ft.)	
		Surface 0		8	
				Clay	
		8		95	
				Cement	
10. TYPE OF DRILLING MACHINE USED		Well construction completed on 5-16-1980			
<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drilling mud & air			
<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air			
<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary			
		<input type="checkbox"/> Jetting with			
		<input type="checkbox"/> Air			
		<input type="checkbox"/> Water			
11. MISCELLANEOUS DATA		Well is terminated 10 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Yield Test: 3 Hrs. at 5 GPM		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth from surface to normal water level 70 Ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping 85 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to Madison laboratory on 5-27-1980					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature Kenneth Copman Registered Well Driller		Complete Mail Address Boscobel, WI, R2 Box 4 53805			