

OCT 17 1977

State of Wisconsin
Department of Natural Resources
Box 7921
Madison, Wisconsin 53707

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15 Rev. 12-76

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Wauseka

2. LOCATION NW Section 3 Township 7N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Richard Folbrocht

OR - Grid or Street No. Street Name ADDRESS R7D1

AND - If available subdivision name, lot & block No. POST OFFICE Wauseka, Wis. 53826

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 150' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to Sewage Sump Clearwater Sump Clearwater Dr. Sewage Sump Clearwater Sump Clearwater Sump Clearwater Sump Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 300'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter 200' Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home 9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>75</u>
<u>limestone</u>	<u>75</u>	<u>200</u>
<u>soft sandstone</u>	<u>200</u>	<u>315</u>
<u>hard shalestone</u>	<u>315</u>	<u>375</u>
<u>hard sandstone</u>	<u>375</u>	<u>430</u>

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>325</u>	<u>6</u>	<u>325</u>	<u>430</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>	<u>Surface</u>	<u>325</u>
	<u>Valley Steel Pitless adaptor</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>325</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 9-26- 1977

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 8 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 300 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 335 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 10-12- 1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coppians Registered Well Driller Complete Mail Address R3 Box 84 Boscobel, Wis. 53805