

NOV 7 1977

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

NOTE:

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Marietta

2. LOCATION SW Section 6 Township 7N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Alan Gerstein

OR - Grid or Street No. Street Name ADDRESS R7D

AND - If available subdivision name, lot & block No. POST OFFICE Boscobel, Wis., 53805

4. Distance in feet from well to nearest: (Record answer in appropriate block) 180'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump				Seepage Pit	
											Seepage Bed	
											Seepage Trench	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well	Nonconforming Existing							
		Pump								
		Tank								

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
------------------------	-------------------------------	--------------------------------	---------------------------------	---	--------------------------

5. Well is intended to supply water for: Pasture

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	105	6	105	310	Clay	Surface	5
						broken limestone	5	90
						hard limestone	90	190
						hard sandstone	190	310

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97 A-53	Surface	105
	Valley Steel		
	Pitless adaptor		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	105

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on Oct. 14 - 1977

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 215 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 23.5 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Nov. 2 - 1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cyprian Complete Mail Address Boscobel Wis. R3 Box 84 53805

Registered Well Driller