

NOTE **MAY 27 1976**

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

(4)

1. COUNTY Crawford CHECK ONE Town Village City NAME Wauzeka

2. LOCATION - 1/4 Section SW SW Section 17 Township 7N Range 5W 3. OWNER AT TIME OF DRILLING Charles Christianson
OR - Grid or street no. Sec 8 Street name per map from msa R4W ADDRESS Wauzeka
AND - If available subdivision name, lot & block no. POST OFFICE Wis. 53826

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	TILE	C. I.	SEWER CONNECTED	INDEPENDENT
20'	40'	40'		

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	75'			90'				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	96	6	96	220	Clay	Surface	40	
						Clay & stone	40	75	
						hard shalestone	75	190	
						sandstone	190	220	

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 18.97 A-53	Surface	96
	Valley Steel		
	Pitless adaptor		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	96

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 5-3-1976

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 170 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 173 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 5-24-1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, Wis. 53805
R3 Box 84

COLIFORM TEST RESULT 335 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS

REV. 3-71