

COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Kauzeka

LOCATION NW Section 10 Township 7N Range 4W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE George Straka

OR Grid or Street No. Street Name ADDRESS R300

AND - If available subdivision name, lot & block No. POST OFFICE Kauzeka, Wis. 53826

Distance in feet from well to nearest: (Record answer in appropriate block)	Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected to:	Storm Bldg. Drain	Storm Bldg. Sewer			
<u>10'</u>	C.I. Other	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other			
Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit		
San. Storm	C.I. Other	Sewer Sewage Sump Clearwater Dr.	C.I. Other				<u>60'</u>		
Private	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)				

Well is intended to supply water for: Country home

DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>7 1/2</u>	Surface	<u>65</u>				<u>loose sand</u>	Surface	<u>30</u>
						<u>shalestone</u>	<u>30</u>	<u>65</u>

CASING, LINER, CURBING AND SCREEN			
Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel RE-1897 A-53</u>	Surface	<u>4.5</u>
<u>Valley Steel Pitless adapter</u>			

GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
<u>loose sand</u>	Surface	<u>30</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jattling with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on 6-6-1977

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Well is terminated 8 inches  above final grade  below

Depth from surface to normal water level 25 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 25 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 6-8-1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copion Registered Well Driller Complete Mail Address Boscobel, Wis. R3 Box 84 53305