


**First Water Quality Test For**  
**WISCONSIN UNIQUE WELL NUMBER A2 847**

Property Owner Mark Tracy Pedretti Telephone Number \_\_\_\_\_  
 Mailing Address RR 1 Box 374  
 City Prarie du Chien State Wis Zip Code \_\_\_\_\_  
 County Crawford County Well Location W Well Completion Date 06/30/88  
 Permit No. \_\_\_\_\_

1. Location (Please type or print using a black pen.)  
 Town  City  Village Fire # (if available) \_\_\_\_\_  
of Prarie du Chien  
 Grid or Street Address or Road Name and Number (if available) \_\_\_\_\_

Well Constructor (Business Name) Corpian Well Drilling Registration # 75  
 Address 501 E. Oak  
 City Roscobel State Wis Zip Code 53805



Subdivision Name \_\_\_\_\_ Lot # \_\_\_\_\_ Block # \_\_\_\_\_  
 Gov't Lot # \_\_\_\_\_ or SE 1/4 of NW 1/4 of Section 4; T 7 N; R 6  E  W

3. Well Type  New  Replacement  Reconstruction/Rehabilitation  
 of well constructed in 19 \_\_\_\_\_  
 Reason for new, reconstructed, replaced, or rehabilitated well? \_\_\_\_\_

Well serves \_\_\_\_\_ of homes and/or cattle  
 (ex: barn, restaurant, church, school, industry, etc.)  
 High Capacity Well?  Yes  No  
 High Capacity Property?  Yes  No

Drilled  Driven Point  Jetted  Other \_\_\_\_\_

5. Well Located on Highest Point of Property, Consistent with the General Layout and Surroundings?  Yes  No  
 Well Located in Floodplain?  Yes  No  
 Distance In Feet From Well To Nearest:  
 1. Landfill \_\_\_\_\_ 2. Building Overhang \_\_\_\_\_ 3. Septic or Holding Tank \_\_\_\_\_ 4. Sewage Absorption Unit \_\_\_\_\_ 5. Nonconforming Pit \_\_\_\_\_ 6. Buried Home Heating Oil Tank \_\_\_\_\_ 7. Buried Petroleum Tank \_\_\_\_\_ 8. Shoreline/Swimming Pool \_\_\_\_\_  
 9. Downspout/Yard Hydrant \_\_\_\_\_ 10. Privy 55 11. Foundation Drain to Clearwater \_\_\_\_\_ 12. Foundation Drain to Sewer \_\_\_\_\_ 13. Building Drain 75  Cast Iron or Plastic  Other \_\_\_\_\_ 14. Building Sewer  Gravity  Pressure  Cast Iron or Plastic  Other \_\_\_\_\_ 15. Collector Sewer \_\_\_\_\_ 16. Clearwater Sump \_\_\_\_\_ 17. Wastewater Sump \_\_\_\_\_ 18. Paved Animal Barn Pen \_\_\_\_\_ 19. Animal Yard or Shelter \_\_\_\_\_ 20. Silo - Type \_\_\_\_\_ 21. Barn Gutter \_\_\_\_\_ 22. Manure Pipe  Gravity  Pressure  Cast Iron or Plastic  Other \_\_\_\_\_ 23. Other Manure Storage \_\_\_\_\_ Other NR 112 Waste Source \_\_\_\_\_ 24. \_\_\_\_\_

6. Drillhole Dimensions

Dia. (in.)	From (ft.)	To (ft.)
10	0 surface	51
6	51	65

Method of constructing upper enlarged drillhole. (If applicable  more than one.)  
 1. Rotary - Mud Circulation  
 2. Rotary - Air  
 3. Rotary - Foam  
 4. Reverse Rotary  
 5. Cable-tool Bit \_\_\_\_\_ in. dia.  
 6. Temp. Outer Casing 10 in. dia. Removed?  Yes  No  
 If no, explain \_\_\_\_\_  
 7. Other \_\_\_\_\_

9. Geology

Type, Caving/Noncaving, Color, Hardness, Etc.	From (ft.)	To (ft.)
<u>IG</u> dirt & loose rock	0	16
<u>FW</u> Limerock & chev.	16	50
<u>LN</u> Limerock & sandrock	50	65

7. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
6	New black steel Plain End	0 surface	51
	CAC ASTM A-53A		
	6x21 #18.97		

10. Static Water Level \_\_\_\_\_ ft. above ground level  
23 ft. below ground surface  
 11. Pump Test  
 Pumping Level 39 ft. below surface  
 Pumping at 5 GPM for 7 hours  
 12. Well Is: 16 in.  Above Grade  Below Grade  
 Developed?  Yes  No  
 Disinfected?  Yes  No  
 Capped?  Yes  No

8. Grout or Other Sealing Material

Method	Kind of Sealing Material	From (ft.)	To (ft.)	Sacks Cement
<u>tramee</u>	<u>Neat Cement</u>	0 surface	51	16

13. Were all unused, noncomplying, or unsafe wells properly filled with sealant?  
 Yes  No If no, explain \_\_\_\_\_  
 14. Signature of Well Constructor Michael O. Beinborn M03 Date Signed 7/17/88  
 Signature of Drill Rig Operator Michael O. Beinborn M03 Date Signed 7/17/88