

1. COUNTY Crawford CHECK ONE Town Village City NAME Hauzeka

2. LOCATION (Number and street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
Hauzeka, Wis. 53826

3. OWNER AT TIME OF DRILLING Mr. Edwin Walters

4. OWNER'S COMPLETE MAIL ADDRESS
NE 1/4 of Sec 7 T7N R5W

5. Distance in feet from well to nearest:		BUILDING	SANITARY SEWER		FLOOR DRAIN		FOUNDATION DRAIN		WASTE WATER DRAIN	
(Record answer in appropriate block)		C. I.	TILE	C. I.	TILE	SEWER CONNECTED	INDEPENDENT	C. I.	TILE	
		10'	20'	20'						
CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE		
C. I.	TILE									
	85'			110'	200'	200'	125'			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS				
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)		
10	Surface	320	6	320	480	Clay	Surface	15		
						loose stone	15	20		

8. CASING, LINER, CURBING, AND SCREEN				10. FORMATIONS				
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)		
6	new black steel plain end - 19.18	Surface	320	limestone	20	125		
				sandstone	125	190		
				limestone	190	300		
				loose stone & crevice	300	310		
				limestone	310	450		
				sandstone	450	480		

9. GROUT OR OTHER SEALING MATERIAL			
Kind	From (ft.)	To (ft.)	
Clay	Surface	15	
Cement	15	320	Well construction completed on 10-23-1968

11. MISCELLANEOUS DATA			
Yield test:	5 Hrs. at	18 GPM	Well is terminated 10 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth from surface to normal water level	400 ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	405 ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to Madison, Wis. laboratory on: 10-28-1968

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphouses, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS 53805 R3 Box 84 Boocabel, Wis.

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
352				