

WELL CONSTRUCTOR'S REPORT

DEPARTMENT OF RESOURCE DEVELOPMENT

Well 6

1. COUNTY <i>Crawford</i>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		NAME <i>Kauseka</i>		
2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.) <i>SW 1/4 of Sec. 9 T7N R5W</i>						
3. OWNER AT TIME OF DRILLING <i>Orris Oswald</i>						
4. OWNER'S COMPLETE MAIL ADDRESS <i>R70 Kauseka, Wis. 53826</i>						
5. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING 15'	SANITARY SEWER C. I. 18'	FLOOR DRAIN C. I. 18'	FOUNDATION DRAIN SEWER CONNECTED	WASTE WATER DRAIN C. I. <input checked="" type="checkbox"/>
CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO
	65'			85'	200'	200'
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)						

6. Well is intended to supply water for:

Farm home

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	60	6	60	90	Clay	Surface	25	
						loose rock & Clay	25	45	
8. CASING, LINER, CURBING, AND SCREEN						sandstone			
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)					
6	new black steel plain end 19.18		Surface	60					
9. GROUT OR OTHER SEALING MATERIAL									
Kind			From (ft.)	To (ft.)					
Clay			Surface	25					
Cement			25	60					

11. MISCELLANEOUS DATA				Well construction completed on <i>6-3-</i> 1968			
Yield test:		8 Hrs. at 12 GPM		Well is terminated 10 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade			
Depth from surface to normal water level 70 ft.				Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth to water level when pumping 70 ft.				Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water sample sent to <i>Madison, Wis.</i>				laboratory on: <i>9-9-</i> 1968			

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Kenneth Coyman</i>		COMPLETE MAIL ADDRESS <i>R3 Box 84 Boeshel, Wis. 53805</i>	
Registered Well Driller			

Please do not write in space below

COLIFORM TEST RESULT 354	GAS -- 24 HRS.	GAS -- 48 HRS.	CONFIRMED	REMARKS
-----------------------------	----------------	----------------	-----------	---------