

NOV 4 1977

State of Wisconsin
Department of Natural Resources
Box 7921
Madison, Wisconsin 53707

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15 Rev. 12-76

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Waunakee

2. LOCATION 1/4 Section NE Section 14 Township 7N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE

OR - Grid or Street No. Street Name ADDRESS Edward E. Budler

AND - If available subdivision name, lot & block No. POST OFFICE Waunakee, Wis., 53826

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To	Storm Bldg. Drain	Storm Bldg. Sewer
<u>8</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
San. Storm	C.I. Other	Sewer Sewage Sump Clearwater Dr.	C.I. Other				<u>75'</u>

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>80</u>	<u>6</u>	<u>80</u>	<u>155</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay & sand</u>	<u>Surface</u>	<u>60</u>
<u>limestone</u>	<u>60</u>	<u>130</u>
<u>hard shalestone</u>	<u>130</u>	<u>155</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.F. 18.97</u>	<u>Surface</u>	<u>80</u>
	<u>A-53</u>		
	<u>Valley Steel</u>		
	<u>Pitless adaptor</u>		

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>80</u>

Well construction completed on 10-6-1977

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 4 GPM

Depth from surface to normal water level 100 Ft.

Depth of water level when pumping 145 Ft. Stabilized Yes No

Well is terminated 10 inches above final grade below

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 10-31-1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cospian Registered Well Driller

Complete Mail Address Boccobell, Wis. R3 Box 84 53805