

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Wauseka	
2. LOCATION 1/4 Section NW Section 16 Township 7N Range 5W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Dave Dombek		ADDRESS RFD	
OR - Grid or Street No. Street Name		POST OFFICE Wauseka, Wis. 53826		AND - If available subdivision name, lot & block No.	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building 60'		Sanitary Bldg. Drain C.I. Other	
		Sanitary Bldg. Sewer C.I. Other		Door Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.	
		Sewage Sump C.I. Other		Clearwater Sump	
		Septic Tank		Holding Tank	
		Sewage Absorption Unit 130'		Seepage Pit Seepage Bed Seepage Trench	
Privy		Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank	
		Subsurface Pumproom Nonconforming Existing		Barn Gutter	
		Animal Barn Pen		Animal Yard	
		Silo With Pit		Glass Lined Storage Facility	
		Silo w/o Pit		Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
		Other (Give Description)			
5. Well is intended to supply water for: Country home			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.) From (ft.) To (ft.)			From (ft.) To (ft.)		
10 Surface 45			Clay & stone Surface 0 30		
6 45 80			hard sandstone 30 80		
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly			From (ft.) To (ft.)		
6 new black steel			0 45		
R.E. 18.97			Surface		
A-53					
Valley Steel					
Pitless adapter					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind			From (ft.) To (ft.)		
Clay			Surface 0 7		
Cement			7 45		
			Well construction completed on 7-12-1978		
11. MISCELLANEOUS DATA			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
Yield Test: 2 Hrs. at 5 GPM			Well is terminated 10 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Depth from surface to normal water level 50 Ft.			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping 56 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to Madison			laboratory on 8-3-1978		

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature **Kenneth Cospian** Registered Well Driller Complete Mail Address **Booscobel, Wis. R3 Box 84 53805**