

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH  
See Instructions on Reverse Side

1. County Crawford Town  Kauszka  
Village   
City  Check one and give name

2. Location 8 miles W. of Kauszka Sec 17 7N 5W  
Name of street and number of premise or Section, Town and Range numbers

3. Owner  or Agent  Zwiefel Brothers  
Name of individual, partnership or firm

4. Mail Address Kauszka, Wis. R. 7. D.  
Complete address required

5. From well to nearest: Building 10 ft; sewer 0 ft; drain 50 ft; septic tank 0 ft;  
dry well or filter bed 0 ft; abandoned well 0 ft.

6. Well is intended to supply water for: farm + home

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	48	6	48	225

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	standard	0	48

9. GROUT:

Kind	From (ft.)	To (ft.)
Clay	0	40
Cement	40	48

11. MISCELLANEOUS DATA:

Yield test: 3 Hrs. at 15 GPM.  
Depth from surface to water-level: 200 ft.  
Water-level when pumping: 200 ft.  
Water sample was sent to the state laboratory at:  
Madison on June 30 1958  
City

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
sandstone	0	40
limestone	40	180
sandstone	180	225

RECEIVED  
JUL 8 1958  
ENVIRONMENTAL  
SANITATION

Construction of the well was completed on:  
November 1957

The well is terminated 6 inches  
 above, below  the permanent ground surface.

Was the well disinfected upon completion?  
Yes  No

Was the well sealed watertight upon completion?  
Yes  No

Signature Kenneth Coplan  
Registered Well Driller

R. 3 Box 36 Boscobel, Wis.  
Complete Mail Address

Please do not write in space below

Rec'd JUL 1 1958 No. 19499

10 ml 10 ml 10 ml 10 ml 10 ml

Ans'd \_\_\_\_\_  
Interpretation **SAFE**

Gas—24 hrs. \_\_\_\_\_  
48 hrs. \_\_\_\_\_  
Confirm \_\_\_\_\_

B. Coli \_\_\_\_\_  
Examiner \_\_\_\_\_