

1. COUNTY Crawford CHECK ONE Town Village City NAME Kauszka

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.) Sec. 22 Town 7N R. 5W RECEIVED

3. OWNER AT TIME OF DRILLING _____ SEP 1966

4. OWNER'S COMPLETE MAIL ADDRESS J. Lamar Lindsay
R 7 & Kauszka SOCIETY ENGINEERING

5. Distance in feet from well to nearest: BUILDING SANITARY SEWER FLOOR DRAIN FOUNDATION DRAIN WASTE WATER DRAIN
(Record answer in appropriate block) C. I. TILE C. I. TILE SEWER CONNECTED INDEPENDENT C. I. TILE

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE
C. I. TILE 100' 0 110' 0 0 0 0 0

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.) 0

6. Well is intended to supply water for: Home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	40	5"	40	105	Clay & loose stone	Surface	15
						Limestone	15	40
						loose sand	40	70
						sandstone	70	91
						Hard shale rock	91	105

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6"	Standard wt.	Surface	40
5"	" "	0	84

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	15
Cement	15	40

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 20 GPM Well is terminated 12 inches above below final grade

Depth from surface to normal water level 80 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 80 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 8-31 1966

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE [Signature] Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 36 Rosobel Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
369				