

NOTE:  
 White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Prairie Du Chien</u>	
2. LOCATION 1/4 Section of Gov't. Lot / <u>SE of SE</u> Section <u>12</u> Township <u>7N</u> Range <u>6W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>J Willard Marshall</u>		ADDRESS <u>Rt 1 Box 340A</u>	
OR - Grid or Street No. Street or Road Name		POST OFFICE <u>Prairie Du Chien Wi</u>		ZIP CODE <u>53821</u>	
AND - If available subdivision name, lot & block No.					
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>15'</u>		Sanitary Bldg. Drain C.I. Other		Sanitary Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Clearwater Sump		Floor Drain Connected To: C.I. Sewer Other Sewer	
Other Sewers C.I. Other		Sewage Sump C.I. Other		Storm Bldg. Drain C.I. Other	
Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench <u>65'</u>		Clearwater Sump		Storm Bldg. Sewer C.I. Other	
Septic Tank <u>56</u>		Holding Tank		Manure Hopper or Retention or Pneumatic Tank	
Privy		Subsurface Pumproom Nonconforming Existing		Barn Gutter	
Pet Waste Pit		Animal Barn Pen		Animal Yard	
Pit: Nonconforming Existing Well Pump Tank		Silo With Pit		Glass Lined Storage Facility	
Temporary Manure Stack or Platform		Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls		Other (Describe)	
Watertight Liquid Manure Tank or Basin		Waste Pond or Land Disposal Unit (Specify Type)			
Manure Pressure Pipe					
Subsurface Gasoline or Oil Tank		5. Well is intended to supply water for: <u>Trailer Home</u>			
6. DRILLHOLE		9. FORMATIONS			
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)		Kind		From (ft.) To (ft.)	
<u>10</u> <u>0</u> <u>42</u> <u>6</u> <u>42</u> <u>60</u>		<u>clay &amp; rock</u>		<u>0</u> <u>20</u>	
		<u>lime rock</u>		<u>20</u> <u>60</u>	
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification Dia. (in.) Mfg. & Method of Assembly		From (ft.) To (ft.)			
<u>6</u> <u>new black steel</u> <u>PE 18.97</u>		<u>0</u> <u>42</u>			
<u>A53 D.T.</u>					
8. GROUT OR OTHER SEALING MATERIAL		10. TYPE OF DRILLING MACHINE USED			
Kind From (ft.) To (ft.)		<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drilling mud & air	
<u>clay</u> <u>0</u> <u>8</u>		<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air	
<u>cement</u> <u>8</u> <u>42</u>		<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary	
				<input type="checkbox"/> Jetting with	
				<input type="checkbox"/> Air	
				<input type="checkbox"/> Water	
11. MISCELLANEOUS DATA		Well construction completed on <u>10-9</u> 19 <u>82</u>			
Yield Test: <u>3</u> Hrs. at <u>7</u> GPM		Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Depth from surface to normal water level <u>30</u> Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping <u>32</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water sample sent to <u>Madison</u> laboratory on <u>11-10</u> 19 <u>82</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Donald C. Kirschbaum</u> Registered Well Driller		Business Name and Complete Mailing Address <u>Dons Well Drilling Rosobel Wi 53805</u>			

37