

NOV 2 - 1973

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Kauzeka

2. LOCATION - 1/4 Section NW Section 28 Township 7N Range 5W 3. OWNER AT TIME OF DRILLING Arthur Schwarz

OR - Grid or street no. Street name ADDRESS RFD Kauzeka,

AND - If available subdivision name, lot & block no. POST OFFICE Wis., 53826

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
<u>15'</u>	<u>25'</u>					

CLEAR WATER DRAIN C. I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		<u>60'</u>			<u>75'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>40</u>	<u>6</u>	<u>40</u>	<u>100</u>	<u>Clay</u>	<u>Surface</u>	<u>10</u>	
						<u>soft sandstone</u>	<u>10</u>	<u>25</u>	
						<u>hard shalestone</u>	<u>25</u>	<u>80</u>	
						<u>sandstone</u>	<u>80</u>	<u>100</u>	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain ends 19.18</u>	<u>Surface</u>	<u>40</u>

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>Clay</u>	<u>Surface</u>	<u>10</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>10</u>	<u>40</u>	Well construction completed on <u>9-24-1973</u>		

11. MISCELLANEOUS DATA		Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade	
Yield test:	<u>3</u> Hrs. at <u>5</u> GPM	Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth from surface to normal water level	<u>60</u> ft.	Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	<u>68</u> ft.		

Water sample sent to Madison laboratory on: 10-29-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>374</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
---------------------------------	---------------	---------------	-----------	---------

REV. 3-71