

JUN 28 1979

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Wauzeka</u>	
2. LOCATION 1/2 Section <u>SE</u> Section <u>31</u> Township <u>6N</u> Range <u>11W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Alice D. Oswald</u>		ADDRESS <u>RFD</u>	
OR Grid or Street No. Street Name <u>SE Sec 32 ?? T7N R5W? 30</u>		AND If available subdivision name, lot & block No.		POST OFFICE <u>Prairie du Chien, WI, 53821</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>8'</u>		Building		Sanitary Bldg. Drain	
		Sanitary Bldg. Sewer		Floor Drain Connected To:	
		Storm Bldg. Drain		Storm Bldg. Sewer	
		San. Storm		C.I. Other	
		Foundation Drain Connected to:		Sewage Sump	
		Sewage Sump		Clearwater Sump	
		Septic Tank		Holding Tank	
		Sewage Absorption Unit <u>65'</u>		Seepage Pit	
		Seepage Bed		Seepage Trench	
Privy		Pet Waste Pit		Pit: Nonconforming Existing	
				Subsurface Pumproom	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: <u>Country home</u>		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.) To (ft.)	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)		<u>Clay</u>		<u>0</u> <u>30</u>	
<u>10</u> <u>0</u> <u>30</u> <u>6</u> <u>30</u> <u>120</u>		<u>loose sand</u>		<u>30</u> <u>80</u>	
		<u>sandstone</u>		<u>80</u> <u>120</u>	
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly		From (ft.) To (ft.)			
<u>6" new black steel P.E. 18.97</u>		<u>0</u> <u>100</u>			
<u>A-53</u>					
<u>Kent Steel</u>					
<u>Pitless adaptor</u>					
8. GROUT OR OTHER SEALING MATERIAL		10. TYPE OF DRILLING MACHINE USED			
Kind From (ft.) To (ft.)		<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drilling mud & air	
<u>Clay</u> <u>0</u> <u>7</u>		<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air	
<u>Cement</u> <u>7</u> <u>30</u>		<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary	
				<input type="checkbox"/> Jetting with	
				<input type="checkbox"/> Air	
				<input type="checkbox"/> Water	
11. MISCELLANEOUS DATA		Well construction completed on <u>6-15-</u> 19 <u>79</u>			
Yield Test: <u>3</u> Hrs. at <u>5</u> GPM		Well is terminated <u>10</u> inches		<input checked="" type="checkbox"/> above final grade	
Depth from surface to normal water level <u>80</u> Ft.		Well disinfected upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth of water level when pumping <u>91</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Water sample sent to <u>Madison</u> laboratory on <u>6-25-</u> 19 <u>79</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Kenneth Copjian</u>		Complete Mail Address <u>R2 Box 4 Boscobel, Wis 53805</u>			
Registered Well Driller					