

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Wauzeka.

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
S.E. 1/4 of N.E. 1/4 - Sec. 32 - Town - 7N. - Range 5W.

3. OWNER AT TIME OF DRILLING Donald McCarthy

4. OWNER'S COMPLETE MAIL ADDRESS Wauzeka, Wis. P.F.D.

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C.I.	TILE	C.I.	SEWER CONNECTED	INDEPENDENT
20ft.				

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C.I.	TILE							
	75ft. <u>now</u>		100ft.		<u>now</u>	<u>now</u>	<u>now</u>	<u>now</u>

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)  
Creep about 100ft. below house.

6. Well is intended to supply water for: Private Home

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10"	Surface	35'	6"	35'	116'	top Soil	Surface	3'	
						Hard Brown <sup>Limestone</sup> <del>rock</del>	3'	35'	
						Sand	35'	90'	
						Green shale	90'	116'	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<del>6"</del>	<del>Steel 19.45</del>	Surface	90'
	with Driveshoe		
6"	new Black Steel		
	19.45 pound per foot		
	Plain end.		

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
neat Cement	Surface	35'

Well construction completed on Sept. 19 1967

11. MISCELLANEOUS DATA

Yield test: 4 Hrs. at 12 GPM Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 20 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 35 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to State Lab. of Hygiene at Madison laboratory on: Sept. 26 1967

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Lewis Harris Registered Well Driller COMPLETE MAIL ADDRESS 327 N. Main St Prairie Du Chem, Wis.

Please do not write in space below

COLIFORM TEST RESULT	GAS -- 24 HRS.	GAS -- 48 HRS.	CONFIRMED	REMARKS
378				