

T. 7 N., R. 6 W.

Emergency well, city of Prairie du Chien  
 From report to State Board of Health, Varner Well Drilling Co., 1948

	Thickness	Depth
Sand, fine to coarse	110	110

72' 4" of 18" pipe to 70; 94' 8" of 12" pipe to depth 91' 4" with space filled with cement

20' of 12" #30 slot Johnson Everdur screen with lead seal and closed bottom

City well No. 6

Sand	138.5	138.5
------	-------	-------

91' 9" of 24" pipe to 89; 91' 8" of 18" pipe with bottom at 89; space filled with cement

48' of #30 slot Johnson Everdur screen with lead packer and bail bottom

Tested at 1640 g.p.m. specific capacity = 124 g.p.m./ft.  
 Water temperature 51 F.

Water level 26 ft.