

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

SEP 19 1974

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City Prairie du Chien NAME

2. LOCATION - 1/4 Section 7N Section 6W Township 7N Range 6W 3. OWNER AT TIME OF DRILLING Gordon E. Olson

OR - Grid or street no. Street name ADDRESS 106 W. Paquette

AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C. I.	TILE
	<u>50'</u>						

CLEAR WATER DRAIN C. I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		<u>85'</u>			<u>125'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Trailer Court

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>6</u>	<u>Surface</u>	<u>130</u>				<u>loose sand</u>	<u>Surface</u>	<u>120</u>	
						<u>course gravel bed</u>	<u>120</u>	<u>130</u>	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18197</u>	<u>Surface</u>	<u>130</u>

8. GROUT OR OTHER SEALING MATERIAL		10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary
<u>loose sand</u>	<u>Surface</u>		<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air
			<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water

Well construction completed on 7-25-1974

11. MISCELLANEOUS DATA		Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade	
Yield test:	<u>3</u> Hrs. at <u>28</u> GPM	Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth from surface to normal water level	<u>60</u> ft.	Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	<u>68</u> ft.		

Water sample sent to Madison laboratory on: 9-16-1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>383</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------