

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH
See Instructions on Reverse Side

1. County Crawford Town Prairie du Chien
 Village City Check one and give name
 2. Location 4 miles N.E. of Prairie du Chien (7N, 6W)
 Name of street and number of premise or Section, Town and Range numbers
 3. Owner or Agent San Lariviere
 Name of individual, partnership or firm
 4. Mail Address Prairie du Chien, Wis. R. 7, S.
 Complete address required
 5. From well to nearest: Building 100 ft; sewer 200 ft; drain 200 ft; septic tank 200 ft;
 dry well or filter bed 200 ft; abandoned well 225 ft.

6. Well is intended to supply water for: farm + home

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	40	6	40	190

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	standard	0	40

9. GROUT:

Kind	From (ft.)	To (ft.)
clay	0	30
Cement	30	40

11. MISCELLANEOUS DATA:

Yield test: 2 Hrs. at 15 GPM.
 Depth from surface to water-level: 140 ft.
 Water-level when pumping: 140 ft.
 Water sample was sent to the state laboratory at:
Madison on June 23 1958
 City

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
miped clay sand	0	30
limestone	30	110
sandstone	110	190

RECEIVED
 JUL 2 1958
 ENVIRONMENTAL
 SANITATION

Construction of the well was completed on:
June 10 1958

The well is terminated 6 inches
 above, below the permanent ground surface.

Was the well disinfected upon completion?
 Yes No

Was the well sealed watertight upon completion?
 Yes No

Signature Kenneth Copiers
 Registered Well Driller

R. 3 Box 36 Boscobel, Wis.
 Complete Mail Address

Please do not write in space below

Rec'd JUN 24 1958 No. 18446

Ans'd _____
 Interpretation SAFE

10 ml 10 ml 10 ml 10 ml 10 ml
 Gas—24 hrs. _____
 48 hrs. _____
 Confirm _____
 B. Coli A
 Examiner _____