

SEP 12 1978

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Prairie du Chien	
2. LOCATION 1/4 Section NE Section 2 Township 7N Range 7W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Mark R. Du Charme		ADDRESS R 3 A	
OR - Grid or Street No. Street Name		AND - If available subdivision name, lot & block No.		POST OFFICE Prairie du Chien, Wis. 53821	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building 25'		Sanitary Bldg. Drain C.I. Other	
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Clearwater Sump	
		Sewage Sump C.I. Other		Clearwater Sump	
Septic Tank		Holding Tank		Sewage Absorption Unit Seepage Pit 75' Seepage Bed Seepage Trench	
Privy		Pet Waste Pit		Pit: Nonconforming Existing	
				Subsurface Pumproom Nonconforming Existing	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: Country home				9. FORMATIONS	
6. DRILLHOLE				Kind	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)				From (ft.) To (ft.)	
10 Surface 0 119 6 119 460				Clay Surface 0 50	
				broken limestone 50 100	
				hard limestone 100 150	
				hard sandstone 150 250	
				limestone 250 460	
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly					
Dia. (in.) From (ft.) To (ft.)					
6 new black steel Surface 0 119					
P.E. 18.97					
A-53					
Valley Steel					
Pitless adaptor					
8. GROUT OR OTHER SEALING MATERIAL					
Kind From (ft.) To (ft.)					
Clay Surface 0 7					
Cement 7 119					
10. TYPE OF DRILLING MACHINE USED					
<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water					
Well construction completed on 8-21-1978					
11. MISCELLANEOUS DATA					
Yield Test: 3 Hrs. at 5 GPM					
Well is terminated 10 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below					
Depth from surface to normal water level 370 Ft. Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Depth of water level when pumping 390 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to Madison laboratory on 9-5-1978					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature Kenneth Coplan Registered Well Driller			Complete Mail Address Boscobel, Wis. R 3 Box 84 53805		