

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

NOV 25 1974

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Bridgeport

2. LOCATION - 1/4 Section SE Section 3 Township 7N Range 6W 3. OWNER AT TIME OF DRILLING Jerry Zinkle
OR - Grid or street no. Street name ADDRESS R70

AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest: BUILDING SANITARY SEWER FLOOR DRAIN FOUNDATION DRAIN WASTE WATER DRAIN
(Record answer in appropriate block) 25' 4' 40' C. I. TILE C. I. TILE SEWER CONNECTED INDEPENDENT C. I. TILE

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE
C. I. TILE 80' 125'

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	63	6	63	155	Clay	Surface	20
						soft sandstone	20	45
						limestone	45	80
						hard shalestone	80	100
						sandstone	100	155

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 18.97	Surface	63

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
Clay	Surface	20	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with Air <input type="checkbox"/> Water
Cement	20	63	Well construction completed on 11-9-1974		

11. MISCELLANEOUS DATA			Well is terminated		Well disinfected upon completion		Well sealed watertight upon completion	
Yield test:	3 Hrs. at	6 GPM	12	inches	<input checked="" type="checkbox"/> above	<input type="checkbox"/> below	final grade	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth from surface to normal water level	104	ft.			<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth to water level when pumping	115	ft.			<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			

Water sample sent to Madison laboratory on: 11-18-1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boscobel Wis. 53805
R3 Box 84

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
395				