

JUN 12 1979

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Prairie du Chien</u>	
2. LOCATION		1/2 Section <u>SE</u>	Section <u>4</u>	Township <u>7N</u>	Range <u>9W</u>
OR - Grid or Street No.		Street Name		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Mark A. Peterson</u>	
AND - If available subdivision name, lot & block No.				ADDRESS <u>RR1</u>	
				POST OFFICE <u>Prairie du Chien, Wis., 53821</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>40'</u>	Sanitary Bldg. Drain C.I.    Other	Sanitary Bldg. Sewer C.I.    Other	Floor Drain Connected To: C.I. Sewer    Other Sewer
		Storm Bldg. Drain C.I.    Other	Storm Bldg. Sewer C.I.    Other	Sewage Absorption Unit <u>85'</u>	
Street Sewer		Foundation Drain Connected to:		Sewage Sump	Clearwater Sump
San.    Storm		Sewer    Clearwater Dr.		C.I.    Other	Septic Tank
Other Sewers C.I.    Other		Sewage Sump		Holding Tank	
Privy		Subsurface Pumproom		Barn Gutter	Animal Barn Pen
Pet Waste Pit		Nonconforming Existing		Animal Yard	Silo With Pit
Pit: Nonconforming Existing				Glass Lined Storage Facility	Silo w/o Pit
Well Pump Tank				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Solid Manure Storage Structure		Other (Give Description)	
Watertight Liquid Manure Tank		Subsurface Gasoline or Oil Tank			
		Waste Pond or Land Disposal Unit (Specify Type)			
5. Well is intended to supply water for: <u>Country Home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>70</u>	<u>6</u>	<u>70</u>	<u>140</u>
7. CASING, LINER, CURBING AND SCREEN			From (ft.)		
Material, Weight, Specification & Method of Assembly			To (ft.)		
Dia. (in.)					
<u>6</u>	<u>new black steel P.E. 18.97</u>		<u>Surface</u>	<u>70</u>	
	<u>A-53</u>				
	<u>Kent Steel</u>				
	<u>Pitless adaptor</u>				
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind			From (ft.)		
To (ft.)			To (ft.)		
<u>Clay</u>			<u>Surface</u> <u>7</u>		
<u>Cement</u>			<u>7</u> <u>70</u>		
			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
11. MISCELLANEOUS DATA			Well construction completed on <u>5-4-1979</u>		
Yield Test: <u>2</u> Hrs. at <u>5</u> GPM			Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Depth from surface to normal water level <u>60</u> Ft.			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <u>76</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <u>Madison</u> laboratory on <u>6-5-1979</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Kenneth Coplan</u>			Complete Mail Address <u>R3 Box 84 Rosabel, Wis. 53805</u>		
Registered Well Driller					