

JAN 14 1983

1. COUNTY **CRAWFORD** CHECK (✓) ONE: Town Village City Name **BRIDGEPORT**

2. LOCATION **SW** 1/4 Section or Gov't. Lot ✓ Section **3** Township **6N** Range **7W** 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE **STEPHEN WELTER**

OR - Grid or Street No. Street or Road Name **R6W** ADDRESS **7ED**

AND - If available subdivision name, lot & block No. POST OFFICE **PRAIRIE DuCHIEU, WI** ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block) **75'**

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer					
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other				
Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank				
San.	Storm	C.I.	Other				C.I.	Other		Seepage Pit	Seepage Bed		
Clearwater Dr.	Clearwater Sump	C.I.	Other				Seepage Trench						
Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
Well	Pump	Nonconforming Existing		Waste Pond or Land Disposal Unit (Specify Type)		Manure Storage Basin		Other (Describe)					
Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank			Concrete Floor Only		Concrete Floor and Partial Concrete Walls					

5. Well is intended to supply water for: **DUCK POND**

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0 Surface	79			
6	79	160			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	NEW BLACK STEEL 18.97	0 Surface	79

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
CEMENT	5 Surface	79

9. FORMATIONS

Kind	From (ft.)	To (ft.)
CLAY	0 Surface	67
LIMESTONE	67	134
SANDSTONE	134	160

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on **12-24** 19**82**

11. MISCELLANEOUS DATA

Yield Test: **5** Hrs. at **8** GPM Well is terminated **12** inches above final grade below

Depth from surface to normal water level **125** Ft. Well disinfected upon completion Yes No

Depth of water level when pumping **140** Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to **MADISON** laboratory on **1-10** 19**83**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature **4 Kenneth Corpian** Registered Well Driller Business Name and Complete Mailing Address **KENNETH CORPIAN & SONS INC. RT. 2 BOX 4 BOSCOBEL, WI 53805**