

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

Well No. 1

CR-197

| | | | | | |
|--|--|---|--|--|--|
| 1. COUNTY Crawford | | CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City Prairie du Chien | | 3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Hornesteader Mobile Home Park | |
| 2. LOCATION OR - Grid or Street No. East 1/2 23 Street or Road Name Sec 23 | | Section 7N Township 6W Range 6W | | ADDRESS R.R. 1 (Bill Herreid, Jr.) POST OFFICE Prairie du Chien, Wis. ZIP CODE 53821 | |
| 4. Distance in feet from well to nearest: (Record answer in appropriate block) | | Building | | Sanitary Bldg. Drain | |
| | | Sanitary Bldg. Sewer | | Floor Drain Connected To: | |
| | | C.I. Other | | C.I. Other C.I. Sewer Other Sewer | |
| | | San. Storm S.I. Other | | Foundation Drain Connected to: | |
| | | Sewer Clearwater Dr. | | Sewage Sump Clearwater Sump | |
| | | Sewage Sump Clearwater Sump | | Clearwater Sump Septic Tank Holding Tank | |
| | | Sewage Sump Clearwater Sump | | Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench | |
| Privy Pet Waste Pit | | Pit: Nonconforming Existing | | Subsurface Pumproom | |
| Well Pump Tank | | Nonconforming Existing | | Barn Gutter Animal Barn Pen Animal Yard Silo With Pit | |
| Temporary Manure Stack or Platform | | Watertight Liquid Manure Tank or Basin | | Manure Pressure Pipe | |
| Manure Storage Basin | | Subsurface Gasoline or Oil Tank | | Waste Pond or Land Disposal Unit (Specify Type) | |
| Concrete Floor Only | | Concrete Floor and Partial Concrete Walls | | Other (Describe) sewer main 55' | |
| 5. Well is intended to supply water for: Trailer Park | | 9. FORMATIONS | | | |
| 6. DRILLHOLE | | Dia. (in.) | | From (ft.) To (ft.) | |
| Dia. (in.) | | From (ft.) | | To (ft.) | |
| 12 1/4 | | Surface | | 63 | |
| 7 1/8 | | 63 | | 77 | |
| 7. CASING, LINER, CURBING AND SCREEN | | Material, Weight, Specification | | From (ft.) To (ft.) | |
| Dia. (in.) | | Mfg. & Method of Assembly | | From (ft.) To (ft.) | |
| 8 | | Std. Blk. pipe | | Surface | |
| 2 1/2 | | 780 wall | | 63 | |
| 0.322 | | weld jts. | | | |
| A-53 | | | | | |
| 0.322 Wall | | | | | |
| see 6/19/85 note from Sam V. | | | | | |
| 8. GROUT OR OTHER SEALING MATERIAL | | Kind | | From (ft.) To (ft.) | |
| cement (Neat) | | Surface | | 63 | |
| 11. MISCELLANEOUS DATA | | Yield Test: 12 Hrs. at 75 GPM | | Well is terminated 12 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade | |
| Depth from surface to normal water level 21 Ft. | | Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| Depth of water level when pumping 53 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | Water sample sent to Sent in by owner to laboratory on ? 19 84 | | | |
| Signature Sam Vander Grint | | Business Name and Complete Mailing SAM'S ROTARY DRILLERS | | ROUTE 2 RANDOLPH, WISCONSIN 53956 | |
| SP. CAP. = 2.3 gpm/ft | | cc: WCD DTM FILE | | WELL LOG BOOK | |