

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Bridgeport

2. LOCATION SE Section 4 Township 7N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Frank Weeks

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, WI. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 100' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump Clearwater Sump Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)

10	Surface	0	58	6	58	180
----	---------	---	----	---	----	-----

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly From (ft.) To (ft.)

6	new black steel P.E. 18.97	0	58
	Kent Steel		
	A-53		
	Pitless adaptor		

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)

Clay	0	7
Cement	7	58

9. FORMATIONS Kind From (ft.) To (ft.)

Clay	0	35
hard limestone	35	96
hard sandstone	96	180

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

Well construction completed on 10-3-1978

11. MISCELLANEOUS DATA Yield Test: 3 Hrs. at 15 GPM Well is terminated 10 inches  above final grade  below

Depth from surface to normal water level 90 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 98 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 10-23-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Kopion Registered Well Driller Complete Mail Address R3 Box 84 Boscobel, WI. 53805