

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

MAY 11 1978

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Prairie du Chien

2. LOCATION $\frac{1}{4}$ Section NE Section 4 Township 7N Range 7W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Kenneth Fernetto

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit		
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump	C.I.	Other	C.I.	Other	C.I.	Other	Seepage Pit	Seepage Bed	Seepage Trench

100'

60'

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
-------	---------------	-----------------------------	---------------------	-------------	-----------------	-------------	---------------	------------------------------	--------------	--------------------------------------

Temporary Manure Stack, Watertight Liquid Manure Tank, Solid Manure Storage Structure, Subsurface Gasoline or Oil Tank, Waste Pond or Land Disposal Unit (Specify Type), Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	89	6	89	160

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>loose stone & clay</u>	Surface	70
<u>limestone</u>	70	160

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	<u>new black steel P.E. 18.97</u>	Surface	89
	<u>A-53</u>		
	<u>Valley Steels</u>		
	<u>Pitless adaptor</u>		

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	Surface	8
<u>Cement</u>	8	89

Well construction completed on 4-26-1978

11. MISCELLANEOUS DATA

Yield Test: 5 Hrs. at 4 GPM

Depth from surface to normal water level 120 Ft.

Depth of water level when pumping 132 Ft. Stabilized Yes No

Well is terminated 12 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 5-8-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Rosobal, Wis. R3 Box 84 53805