

OCT 27 1978

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Prairie du Chien</u>	
2. LOCATION 1/2 Section <u>NE</u> Section <u>4</u> Township <u>7N</u> Range <u>7W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Roger Moore</u>		ADDRESS <u>Mill Coulee Road</u>	
OR - Grid or Street No.    Street Name		ADDRESS <u>(6)</u>		POST OFFICE <u>Prairie du Chien, Wis. 53821</u>	
AND - If available subdivision name, lot & block No.					
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>8'</u>		Sanitary Bldg. Drain	
		Sanitary Bldg. Sewer		Floor Drain Connected To:	
		Storm Bldg. Drain		Storm Bldg. Sewer	
		San. C.I.		C.I.    Other	
		Other Sewers		C.I.    Other	
		Foundation Drain Connected to:		Sewage Sump	
		Sewage Sump		Clearwater Sump	
		Sewage Sump		Septic Tank	
		Sewage Sump		Holding Tank	
		Sewage Sump		Sewage Absorption Unit <u>85'</u>	
		Sewage Sump		Seepage Pit	
		Sewage Sump		Seepage Bed	
		Sewage Sump		Seepage Trench	
Privy		Pet Waste Pit		Pit: Nonconforming Existing	
				Well	
				Pump	
				Tank	
		Subsurface Pumproom		Barn Gutter	
		Nonconforming Existing		Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: <u>Country home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.)    From (ft.)    To (ft.)    Dia. (in.)    From (ft.)    To (ft.)			From (ft.)    To (ft.)		
<u>10</u> <u>Surface</u> <u>92</u> <u>6</u> <u>92</u> <u>160</u>			<u>Clay &amp; loose stone</u> <u>Surface</u> <u>0</u> <u>32</u>		
			<u>broken limestone</u> <u>32</u> <u>85</u>		
			<u>hard limestone</u> <u>85</u> <u>160</u>		
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly					
Dia. (in.)    From (ft.)    To (ft.)					
<u>6</u> <u>new black steel</u> <u>0</u> <u>92</u>					
<u>RE. 18.97</u> <u>Surface</u>					
<u>A-53</u>					
<u>Kent Steel</u>					
<u>Pitless adaptor</u>					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind			From (ft.)    To (ft.)		
<u>Clay</u>			<u>Surface</u> <u>0</u> <u>8</u>		
<u>Cement</u>			<u>8</u> <u>92</u>		
			Well construction completed on <u>10-9-1978</u>		
11. MISCELLANEOUS DATA			Yield Test: <u>3</u> Hrs. at <u>5</u> GPM		
Depth from surface to normal water level <u>100</u> Ft.			Well is terminated <u>8</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Depth of water level when pumping <u>110</u> Ft.    Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <u>Madison</u> laboratory on <u>10-23-1978</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Kenneth Copian</u> Registered Well Driller			Complete Mail Address <u>Boscobel, Wis.</u> <u>R3 Box 84</u> <u>53805</u>		

4060