

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

JUN 12 1979

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Prairie du Chien</u>																			
2. LOCATION 1/4 Section <u>SW</u> Section <u>5</u> Township <u>7N</u> Range <u>7W</u> OR - Grid or Street No. Street Name AND - If available subdivision name, lot & block No.		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Randall O. Nash</u>		ADDRESS <u>RR 1</u> POST OFFICE <u>Prairie du Chien, Wis., 53821</u>																			
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>30'</u>		Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer											
		C.I.		Other		C.I.		Other		C.I.		Other											
Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank											
San.		Storm		C.I.		Other		Sewer		Clearwater Dr.		Sewage Sump											
Privy		Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard											
				Well		Nonconforming Existing																	
				Pump																			
				Tank																			
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)													
5. Well is intended to supply water for: <u>Country home</u>						9. FORMATIONS																	
6. DRILLHOLE						Kind																	
Dia. (in.)						From (ft.)						To (ft.)											
10						Surface						70											
70						6						70											
140						Clay						Surface											
						limestone						40											
						sandstone						120											
												140											
7. CASING, LINER, CURBING AND SCREEN						Material, Weight, Specification & Method of Assembly						From (ft.)						To (ft.)					
6						new black steel						0						70					
						Kent steel						Surface											
						P.E. 18.97																	
						A-53																	
						Pitless adaptor																	
8. GROUT OR OTHER SEALING MATERIAL						Kind						From (ft.)						To (ft.)					
						Clay						Surface						7					
						Cement						7						70					
11. MISCELLANEOUS DATA						Yield Test: <u>3</u> Hrs. at <u>5</u> GPM						Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below											
						Depth from surface to normal water level <u>60</u> Ft.						Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No											
						Depth of water level when pumping <u>72</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No						Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No											
Water sample sent to <u>Madison</u> laboratory on <u>6-5-1979</u>																							
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.																							
Signature <u>Kenneth Coyman</u> Registered Well Driller						Complete Mail Address <u>Boscobel, Wis.</u> <u>RR3 Box 84</u> <u>53805</u>																	