

AUG 19 1977

State of Wisconsin  
Department of Natural Resources  
Box 7921  
Madison, Wisconsin 53707

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
Form 3300-15 Rev. 12-76

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Prarie du Chien

2. LOCATION SW Section 5 Township T7N Range R6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Pat Reed

OR - Grid or Street No. Street Name ADDRESS

AND - If available subdivision name, lot & block No. POST OFFICE Prarie du Chien, Wis

4. Distance in feet from well to nearest: (Record answer in appropriate block) 10

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
San. Storm	C.I. Other	Sewer Sewage Sump Clearwater Dr.	C.I. Other				Seepage Pit Seepage Bed Seepage Trench <u>70</u>

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well Pump Tank	Nonconforming Existing							

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>40</u>			
<u>6</u>	<u>40</u>	<u>84</u>			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>22</u>
<u>Mag lime</u>	<u>22</u>	<u>84</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6"</u>	<u>New steel T &amp; C 19.45</u>	<u>Surface</u>	<u>40</u>
	<u>A-53 Youngstown</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Cement</u>	<u>Surface</u>	<u>40</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on 4-26 19 77

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 20 GPM

Depth from surface to normal water level 41 Ft.

Depth of water level when pumping 41 Ft. Stabilized  Yes  No

Well is terminated 8 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on Aug 11 19 77

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph J. Faherty Registered Well Driller

Complete Mail Address Faherty Drilling Co., Inc.  
1120 Broadway  
PLATTEVILLE, WISCONSIN 53818