

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

JUL 29 1974
NOTE

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City Prairie Du Chien NAME

2. LOCATION - 1/4 Section 1 SW Section 6 Township T7N Range R6W 3. OWNER AT TIME OF DRILLING Ralph Pennekamp

OR - Grid or street no. Street name ADDRESS

AND - If available subdivision name, lot & block no. POST OFFICE Platteville

4. Distance in feet from well to nearest: BUILDING SANITARY SEWER FLOOR DRAIN FOUNDATION DRAIN WASTE WATER DRAIN
C. I. TILE C. I. TILE SEWER CONNECTED INDEPENDENT C. I. TILE
(Record answer in appropriate block) 30

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE
C. I. TILE 65

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: farm

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	107				Clay	Surface	15
6	107	110				sand + gravel	15	40
7. CASING, LINER, CURBING, AND SCREEN						gravel	40	60
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)		Shale with gravel	60	70
6	New Steel 4" x C 19.15		Surface	107		gravel	70	106
						sandstone	106	110

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	Surface	107

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary

Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on May 10 1974

11. MISCELLANEOUS DATA

Yield test: 2 Hrs. at 150 GPM

Well is terminated 8 inches above below final grade

Depth from surface to normal water level 20 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 50 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: July 24 1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Ralph Faherty Registered Well Driller COMPLETE MAIL ADDRESS FAHERTY DRILLING CO., INC.
1120 Broadway
PLATTEVILLE, WISCONSIN 53818

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
411				

REV. 3-71