

**WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH**

CR-165-U  
Vol 6

See Instructions on Reverse Side

1. County Crawford Town   
Village  Prairie Du Chien  
City  Check one and give name

2. Location Section 7 Town 7 Range 6W  
Name of street and number of premise or Section, Town and Range numbers

3. Owner  or Agent  Kenneth Murphy  
Name of individual, partnership or firm

4. Mail Address Prairie Du Chien; Wisconsin  
Complete address required

5. From well to nearest: Building 20 ft; sewer 10 ft; drain \_\_\_\_\_ ft; septic tank 60 ft;  
 dry well or filter bed \_\_\_\_\_ ft; abandoned well \_\_\_\_\_ ft.

6. Well is intended to supply water for: Home

**7. DRILLHOLE:**

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	55			
6	55	132			

**8. CASING AND LINER PIPE OR CURBING:**

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	standard pipe	0	121

**9. GROUT:**

Kind	From (ft.)	To (ft.)
clay	0	55

**11. MISCELLANEOUS DATA:**

Yield test: 2 Hrs. at 10 GPM.  
 Depth from surface to water-level: 47 ft.  
 Water-level when pumping: 47 ft.  
 Water sample was sent to the state laboratory at:  
Madison on Nov. 23 1965  
City

**10. FORMATIONS:**

Kind	From (ft.)	To (ft.)
0 to 8 Drift	0	8
Limestone	8	55
Sand & Gravel	55	60
Jordan Sandstone	60	132

Construction of the well was completed on:

Nov. 16 1965

The well is terminated 10 inches  above, below  the permanent ground surface.

Was the well disinfected upon completion?  
 Yes  No

Was the well sealed watertight upon completion?  
 Yes  No

Signature Duane Lubbers Farmersburg, Iowa  
Registered Well Driller Complete Mail Address

Please do not write in space below

Rec'd \_\_\_\_\_ No. \_\_\_\_\_  
 Ans'd \_\_\_\_\_  
 Interpretation \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

10 ml 10 ml 10 ml 10 ml 10 ml

Gas—24 hrs. \_\_\_\_\_  
 48 hrs. \_\_\_\_\_  
 Confirm \_\_\_\_\_  
 B. Coli \_\_\_\_\_  
 Examiner \_\_\_\_\_