

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15
Rev. 10-75

FEB 18 1977

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Prairie du Chem

2. LOCATION 1/4 Section NW Section 7 Township 7N Range 2W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Ed Schneider

OR - Grid or Street No. Street Name ADDRESS

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chem

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit

San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. Clearwater Sump C.I. Other

Septic Tank 90

Sewage Absorption Unit: Seepage Pit, Seepage Bed 106, Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	127			
6	127	244			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6"	New steel to C 19.45 Surface		
	A-53 youngstown	127	

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	Surface	127

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Sand & fine gravel	Surface	30
sand & gravel	30	120
gravel & sand	120	127
Trempalau lime	127	180
" sand	180	244

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 7-7 1976

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 20 GPM Well is terminated 8 inches above final grade below

Depth from surface to normal water level 45 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 175 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Feb 8 1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph J. Faherty
416 Registered Well Driller

Complete Mail Address **PROPERTY DRILLING CO., INC.**
1120 Broadway
PLATTEVILLE, WISCONSIN 53818