

FEB 18 1977

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Prairie du Chien

2. LOCATION SW 8 T7N R6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Frank Fisher

OR - Grid or Street No. Street Name ADDRESS Prairie du Chien, Wis

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, Wis

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 20 Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Clearwater Sump Sewage Sump Clearwater Sump Clearwater Sump Sewage Sump Clearwater Sump Clearwater Sump

65

80

5. Well is intended to supply water for: home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	377			
6	377	520			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6"	New Steel 70c 19.45 A 53 yumpston	Surface	377

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	Surface	377

9. FORMATIONS

Kind	From (ft.)	To (ft.)
clay	Surface	43
galena lime	43	80
Old Rock	80	92
Trenton	92	147
St Peter Sand	147	230
Limestone	230	240
Sandstone	240	260
May lime	260	520

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 1-29-76

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 25 GPM Well is terminated 8 inches above final grade below

Depth from surface to normal water level 420 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 420 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Feb 8 1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph Faherty Registered Well Driller

Complete Mail Address Faherty Drilling Co 1120 Broadway Platteville, Wis