

SEP 8 1976

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Bridgeport

2. LOCATION NE Section 8 Township 7N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
OR - Grid or Street No. Street Name ADDRESS Glen Beneker
R 7 W
AND - If available subdivision name, lot & block No. POST OFFICE Pravinda Chen, WI, 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>20'</u>	C.I. <u>30'</u> Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other
Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank
San. Storm	C.I. Other	Sewer Sewage Sump Clearwater Dr.	C.I. Other	Clearwater Sump	Holding Tank
Privy	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard
Pet Waste Pit	Well Pump Tank	Nonconforming Existing			Silo With Pit
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)

Street Sewer: San. Storm
Other Sewers: C.I. Other
Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.
Sewage Sump: C.I. Other
Clearwater Sump: Clearwater Sump
Septic Tank: 60'
Holding Tank: 30'
Sewage Absorption Unit: Seepage Pit Seepage Bed Seepage Trench

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>6</u>	<u>Surface</u>	<u>110</u>			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>loose sand</u>	<u>Surface</u>	<u>80</u>
<u>shalestone</u>	<u>80</u>	<u>110</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>	<u>Surface</u>	<u>94</u>
	<u>Valley Steel</u>		
	<u>Pitless adaptor</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>loose sand</u>	<u>Surface</u>	<u>80</u>

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

Well construction completed on 8-14-1976

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 60 Ft.

Depth of water level when pumping 60 Ft. Stabilized Yes No

Well is terminated 10 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 8-30-1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cupian Registered Well Driller Complete Mail Address R3 Box 84 Boscobel, Wis. 53805