

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

27735 ✓

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY <b>Crawford</b>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		NAME <b>Bridgeport</b>	
2. LOCATION - 1/4 Section <b>NE</b> Section <b>9</b> Township <b>7N</b> Range <b>6W</b>		3. OWNER AT TIME OF DRILLING <b>Carl E. Achenbach</b>			
OR - Grid or street no.		Street name		ADDRESS <b>R1</b>	
AND - If available subdivision name, lot & block no.		POST OFFICE <b>Prairie Du Chien, Wis. 53821</b>			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED
		<b>18'</b>	<b>24'</b>	<b>28'</b>	INDEPENDENT
					WASTE WATER DRAIN C.I.
					TILE
CLEAR WATER DRAIN C.I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN
	<b>70'</b>			<b>85'</b>	SILO
					ABANDONED WELL
					SINK HOLE
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)					
5. Well is intended to supply water for: <b>Country home</b>					
6. DRILLHOLE			9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<b>10</b>	<b>Surface</b>	<b>40</b>	<b>6</b>	<b>40</b>	<b>120</b>
					Kind
					<b>Clay</b>
					<b>limestone</b>
					<b>hard sandstone</b>
					From (ft.)
					<b>Surface</b>
					<b>15</b>
					<b>50</b>
					<b>120</b>
7. CASING, LINER, CURBING, AND SCREEN					
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)	
<b>6</b>	<b>new black steel plain end 19.18</b>		<b>Surface</b>	<b>40</b>	
	<b>Clay</b>		<b>0</b>	<b>15</b>	
	<b>Cement</b>		<b>15</b>	<b>40</b>	
8. GROUT OR OTHER SEALING MATERIAL					
Kind		From (ft.)	To (ft.)		
<b>Clay</b>		<b>Surface</b>	<b>15</b>		
<b>Cement</b>		<b>15</b>	<b>40</b>		
10. TYPE OF DRILLING MACHINE USED					
<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Direct Rotary		<input type="checkbox"/> Reverse Rotary	
<input type="checkbox"/> Rotary - air w/drilling mud		<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air		<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water	
Well construction completed on <b>7-6-1973</b>					
Well is terminated <b>10</b> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade					
Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
11. MISCELLANEOUS DATA					
Yield test: <b>2</b> Hrs. at <b>15</b> GPM		Depth from surface to normal water level <b>80</b> ft.			
		Depth to water level when pumping <b>86</b> ft.			
Water sample sent to <b>Madison</b>			laboratory on: <b>7-11-1973</b>		
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.					
SIGNATURE <b>Kenneth Coplan</b> Registered Well Driller			COMPLETE MAIL ADDRESS <b>Boacobel, R3 Box 84 Wis., 53805</b>		
Please do not write in space below					
COLIFORM TEST RESULT <b>425</b>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS	
REV. 3-71					