

SEP 8 1976

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Bridgeport</u>													
2. LOCATION 1/4 Section <u>SE</u> Section <u>10</u> Township <u>7N</u> Range <u>6W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE		ADDRESS <u>Jack's Construction Co., Inc.</u>													
OR - Grid or Street No. Street Name		POST OFFICE <u>Prairie du Chien, Wis. 53821</u>		AND - If available subdivision name, lot & block No.													
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>15'</u>	Sanitary Bldg. Drain C.I. <u>25'</u> Other	Sanitary Bldg. Sewer C.I.	Floor Drain Connected To: C.I. Sewer Other Sewer												
Street Sewer San. Storm		Other Sewers C.I. Other	Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.	Sewage Sump C.I. Other	Clearwater Sump Septic Tank Holding Tank												
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank	Subsurface Pumphoom Nonconforming Existing	Barn Gutter Animal Barn Pen Animal Yard Silo With Pit	Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit												
Temporary Manure Stack		Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)												
5. Well is intended to supply water for: <u>Country home</u>		9. FORMATIONS															
6. DRILLHOLE		Dia. (in.)		From (ft.)		To (ft.)		Kind		From (ft.)		To (ft.)					
<u>10</u>		<u>Surface</u>		<u>63</u>		<u>6</u>		<u>63</u>		<u>200</u>		<u>Clay & sand</u>		<u>Surface</u>		<u>20</u>	
												<u>soft sandstone</u>		<u>20</u>		<u>40</u>	
												<u>hard sandstone</u>		<u>40</u>		<u>200</u>	
7. CASING, LINER, CURBING AND SCREEN		Material, Weight, Specification & Method of Assembly		From (ft.)		To (ft.)											
<u>6</u>		<u>new black steel P.E. 18.97</u>		<u>Surface</u>		<u>63</u>											
		<u>A-53</u>															
		<u>Valley Steel</u>															
		<u>Pitless Unit</u>															
8. GROUT OR OTHER SEALING MATERIAL		Kind		From (ft.)		To (ft.)		10. TYPE OF DRILLING MACHINE USED									
<u>loose sand</u>		<u>Surface</u>		<u>8</u>		<u>8</u>		<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water									
<u>Cement</u>		<u>8</u>		<u>63</u>													
11. MISCELLANEOUS DATA		Yield Test: <u>3</u> Hrs. at <u>5</u> GPM		Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		Well construction completed on <u>8-9-</u> 19 <u>76</u>											
Depth from surface to normal water level <u>120</u> Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Depth of water level when pumping <u>122</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No											
Water sample sent to <u>Madison</u> laboratory on <u>8-30-</u> 19 <u>76</u>																	
Signature <u>429</u> <u>Kenneth Coplan</u> Registered Well Driller		Complete Mail Address <u>Boscobel</u> <u>R3 Box 84</u> <u>Wis. 53805</u>															

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.