

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Bridgeport

2. LOCATION 1/4 Section NE Section 11 Township 7N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 OR - Grid or Street No. Street Name ADDRESS John Forst
RFD

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, Wis., 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer: San. Storm C.I. Other
 Other Sewers: C.I. Other
 Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Clearwater Sump
 Sewage Sump: C.I. Other
 Clearwater Sump
 Septic Tank: 60
 Holding Tank
 Sewage Absorption Unit: 75'
 Seepage Pit
 Seepage Bed
 Seepage Trench

Privy: Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank
 Subsurface Pumproom: Nonconforming Existing
 Barn Gutter
 Animal Barn Pen
 Animal Yard
 Silo With Pit
 Glass Lined Storage Facility
 Silo w/o Pit
 Earthen Silage Storage Trench Or Pit

Temporary Manure Stack
 Watertight Liquid Manure Tank
 Solid Manure Storage Structure
 Subsurface Gasoline or Oil Tank
 Waste Pond or Land Disposal Unit (Specify Type)
 Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	40	6	40	160	Clay	Surface	25
						hard limestone	25	100
						hard sandstone	100	160

7. CASING, LINER, CURBING AND SCREEN
 Material, Weight, Specification & Method of Assembly

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	40
new black steel P.E. 18.97		
A-53		
Valley Steel		
Pitless adaptor		

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	40

Well construction completed on 10-18-1978

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 5 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 90 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 100 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 11-8-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boocobah, Wis., R3 Box 84 53805