

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

MAY 21 1973

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY <i>Crawford</i>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			NAME <i>Bridgeport</i>	
2. LOCATION - 1/4 Section <i>NE</i> Section <i>11</i> Township <i>7N</i> Range <i>6W</i>				3. OWNER AT TIME OF DRILLING <i>Kenneth Rhernecker</i>		
OR - Grid or street no.		Street name		ADDRESS <i>R7D</i>		
AND - If available subdivision name, lot & block no.				POST OFFICE <i>Prairie du Chien, Wis.</i>		
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING 8'	SANITARY SEWER C. I. 15'	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED/INDEPENDENT	WASTE WATER DRAIN C. I. 25'
CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD 70'	BARN	SILO
				ABANDONED WELL		SINK HOLE

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for:
Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
2 6	Surface	120				<i>loose sand</i>	Surface	70	
						<i>sandstone</i>	70	105	
						<i>limestone</i>	105	120	
7. CASING, LINER, CURBING, AND SCREEN									
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)					
6	<i>new black steel plain end 19.18</i>		Surface	83					

8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED			
Kind		From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	
<i>loose sand</i>		Surface	70	<input type="checkbox"/> Rotary - air w/drilling mud	<input type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water	
<i>sandstone</i>				Well construction completed on <i>5-1-</i> 19 <i>73</i>			

11. MISCELLANEOUS DATA				Well is terminated <i>12</i> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade			
Yield test:	<i>3</i> Hrs. at	<i>12</i> GPM					
Depth from surface to normal water level		<i>70</i> ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
Depth to water level when pumping		<i>74</i> ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				

Water sample sent to *Madison* laboratory on: *5-16-* 19 *73*

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Kenneth Copian</i> Registered Well Driller	COMPLETE MAIL ADDRESS <i>Boocobell, R3 Box 84, Wis., 53805</i>
--	---

COLIFORM TEST RESULT <i>435</i>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------